

Loss Prevention Certification Board



CERTIFICATE OF INSTALLER APPROVAL

This is to certify

VIPOND FIRE PROTECTION LIMITED

10 – 12 Glenfield Road, Kelvin Industrial Estate, East Kilbride, Lanarkshire G75 0RA

has complied with the requirements identified in

LPS 1048-1: Issue 4 : September 2003

as a

Level 4 Approved Sprinkler Contractor


and is authorised to use the LPCB mark on documentation directly relating to Sprinkler Systems which are designed, installed and serviced to the installation standards listed in the LPS 1048-1 scheme document.

Certificate No. ASC-024

Issued 15 November 2004

Signed on behalf of the LPCB

E J MICHAELIS *EJ Michaelis*



This Certificate is issued and held in force subject to the corresponding ISO 9001 Certificate being maintained.

Schedule

Approved under the LPS 1048 scheme to undertake the following Categories of Work:

- A** Pre-calculated ordinary hazard systems, installations, extensions and alterations (excluding water supplies)
- B** Pre-calculated high hazard systems, installations, extensions and alterations (excluding water supplies)
- C** Town's main water supplies
- D** Pumped water supplies
- E** Base build contracts (pre-calculated design principles)
- F** Systems, installations, extensions and alterations involving FHC design principles

Approved to issue LPS 1048 Certificates of Conformity for all Categories of Work, supervision not required.